



中国国家强制性产品认证证书

证书编号: 2012010309537267

委托人名称、地址

Schneider Electric Korea Ltd.
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

生产者(制造商)名称、地址

Schneider Electric Korea Ltd.
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

生产企业名称、地址

Schneider Electric Korea Ltd.
63-5 Seokam-ro 1-gil, Iksan City, Jun Book, Korea

产品名称和系列、规格、型号

电子式过载继电器

3DE, 3EZ, FDE, FEZ (型号解释详见附件); $U_i=AC690V; U_e=AC690V; I_e: (0.5A-60A) \times 0.9$; 脱扣级别: 2, 3, 5E, 10E, 20E, 30E, 40; 3P; 配用的辅助触头: AC-15: AC250V/3A, DC-13: DC30V/1A

产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2017年02月21日 有效期至: 2022年02月21日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2012年04月17日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1608005



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2012010309537267

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Korea Ltd.
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Korea Ltd.
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

NAME AND ADDRESS OF THE FACTORY

Schneider Electric Korea Ltd.
63-5 Seokam-ro 1-gil, Iksan City, Jun Book, Korea

NAME, MODEL AND SPECIFICATION

Electronic Overload Relay

3DE, 3EZ, FDE, FEZ; $U_i=AC690V; U_e=AC690V; I_e: (0.5A-60A) \times 0.9; Trip$
Class: 2, 3, 5E, 10E, 20E, 30E, 40; 3P; Auxiliary Contact: AC-15: AC250V/3A, DC-
13: DC30V/1A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-C03-02:2014).

Date of issue: Feb. 21, 2017 Date of expiry: Feb. 21, 2022

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Apr. 17, 2012

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2012010309537267

纸号: 1608005

型号的解释:

$\frac{FEZ}{1}$	-	$\frac{C}{2}$	-	$\frac{WR}{3}$	$\frac{D}{4}$	$\frac{Z7}{5}$	$\frac{I}{6}$	$\frac{A}{7}$	$\frac{Q}{8}$
-----------------	---	---------------	---	----------------	---------------	----------------	---------------	---------------	---------------

1. 型号代号

电子式过载继电器:

型号	功能
3DE:	Overcurrent, Undercurrent, Phase loss, Phase reversal, Unbalance, Locked Rotor, stall,
3EZ:	Overcurrent, Undercurrent, Phase loss, Phase reversal, Unbalance, Locked Rotor, stall, Ground Fault
FDE:	Overcurrent, Undercurrent, Phase loss, Phase reversal, Unbalance, Locked Rotor, stall
FEZ:	Overcurrent, Undercurrent, Phase loss, Phase reversal, Unbalance, Locked Rotor, stall, Ground Fault

2. CCC 认证产品

3. 电流范围

WR: (0.5A~60A)×0.9

外接电流互感器, H1:CT100 型, HH:CT150 型, H2:CT200 型, H3:CT300 型, H4:CT400 型

4. 输出触头类型

A: 1 常开(97, 98)+1 常开(57, 58)(仅 3EZ, FEZ)

D: 1 常开(97, 98)+1 常闭(95, 96)+1 常开(07, 08)(仅 3DE, FDE)

5. 控制电路电源电压及频率:

M7: 220 VAC, 50/60Hz

F7: 110 VAC, 50/60Hz

Z7: 85~250VAC/DC, 50/60Hz (仅 FDE, FEZ 端子类型)

B: 24 VAC/DC, 50/60Hz

6. 接线端子类型

W: 直通型(无主电路接线端子)

T: 具有主电路接线端子(仅 FDE, FEZ)

7. 接地故障电流范围(仅 3EZ, FEZ)

A: 0.02A~3A

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2012010309537267

纸号: 1608005

B: 0.2A~10A

8. 产品用途

Q: 适用于出口

空白: 本地产品

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

