



中国国家强制性产品认证证书

证书编号: 2013010309664018

委托人名称、地址

Schneider Electric Korea Ltd.
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

生产者(制造商)名称、地址

Schneider Electric Korea Ltd.
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

生产企业名称、地址

Schneider Electric Korea Ltd.
63-5 Seokam-ro 1-gil, Iksan City, Jun Book, Korea

产品名称和系列、规格、型号

电子式过载继电器

EOCRSS-05, EOCRSS-30, EOCRSS-60; U_i : 690V; U_e : AC690V; I_e : $0.9 \times (0.5A-6A)$, $0.9 \times (3A-30A)$, $0.9 \times (5A-60A)$; 脱扣级别: 2E, 3E, 5E, 10E; 2P; IP20; 配用的辅助触头: 1NO1NC; I_{th} : 3A; U_e/I_e : AC-15: AC250V/3A, DC-13: DC30V/3A

产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则
CNCA-01C-011: 2007的要求, 特发此证。

发证日期: 2013年12月18日 有效期至: 2018年12月18日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 0870851



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2013010309664018

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Korea Ltd.
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Korea Ltd.
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

NAME AND ADDRESS OF THE FACTORY

Schneider Electric Korea Ltd.
63-5 Seokam-ro 1-gil, Iksan City, Jun Book, Korea

NAME, MODEL AND SPECIFICATION

Electronic Overload Relay

EOCRSS-05, EOCRSS-30, EOCRSS-60; Ui:690V; Ue:AC690V; Ie:0.9×(0.5A-6A), 0.9×(3A-30A), 0.9×(5A-60A); Tripping Class:2E, 3E, 5E, 10E; 2P; IP20; Auxiliary Contact:1N01NC; Ith=3A; Ue/Ie:AC-15:AC250V/3A, DC-13:DC30V/3A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Dec.18, 2013 Date of expiry: Dec.18, 2018

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 0870851



中国国家强制性产品认证证书

变更结论

Modification Approval

证书编号Certificate No.: 2013010309664018

申请编号Application No.: A2014CCC0309-1870382

申请人Applicant: Schneider Electric Korea Ltd. Schneider Electric Korea Ltd.

证书编号Certificate No. (变更前Original): 2013010309664018

证书编号Certificate No. (变更后Present):

变更产品名称 电子式过载继电器

Name of Product Modified: Electronic Overload Relay

型号Model/Type: EOCRSS-05, EOCRSS-30, EOCRSS-60; Ui: 690V; Ue: AC690V; Ie: 0.9 × (0.5A-6A), 0.9 × (3A-30A), 0.9 × (5A-60A); 脱扣级别: 2E, 3E, 5E, 10E; 2P; IP20; 配用的辅助触头: 1NO1NC; Ith=3A; Ue/Ie: AC-15: AC250V/3A, DC-13: DC30V/3A

变更情况Situation of Modification:

见附件See Annex:

序号	项目Item	变更前Original	变更后Present
1	外壳增加装饰用部件	装饰用部件: 无	装饰用部件: PA66/AFR450X2 Eurostar Starflam
2	电子组件板制造商 (生产厂) 名称笔误更正	TIANJIN PRONTRONICS CIRCUIT CORP	SAEM ELECTRONICS

Above Modification is approved. The present will replace the original.

现批准以上变更。

批准日期 (Date): 2014-11-10

第 1 页 / 共 1 页



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

